



Mine Safety Appliances Company • Instrument Division • P.O. Box 427 • Pittsburgh, PA 15230-0427

Telephone: (800) MSA-INST

February 20, 2001

To whom it may concern:

MSA P/N 483756, an oxygen sensor used in various MSA Instruments, is considered an article as defined in 29CFR 1910.1200 (c). Articles are exempt from the Hazard Communication Standard and no MSDS is required for this product. In order to aid in your understanding the contents of this sensor the following table lists potential hazardous components within the sensor at the time of manufacture.

POTENTIAL HAZARDOUS COMPONENTS	QUANTITY
Aqueous Potassium Hydroxide	\leq 5 ml
Potassium Tartrate	\leq 2 grams
Lead (all or part of the lead may be in the form of lead oxide)	\leq 20 grams

Please note that the environment in which you used the sensor may have impacted its contents and that it is your responsibility to dispose of the sensor in accordance with local, state, and federal laws and regulations. Please provide this information to your regulatory affairs and/or safety officer.

Should you have additional questions contact MSA at the above phone number.

